



LISTING INFORMATION OF GGI Glass Distributors - PyroFrames up to 120 Minute Non-Load  
Bearing Glazed Wall Assembly

SPEC ID: 40243

GGI Glass Distributors Corp.  
101 Venture Way

Secaucus, NJ 07094

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**GGI - PyroFrames™ up to 120 Minute Non-Load Bearing Glazed Wall Assembly**

Frames shall be manufactured from minimum 14 gauge cold rolled galvanized steel tubes. For installation in up to 2 hour locations (dependant upon glazing), in steel/wood stud, drywall, or masonry openings.

Assembly Size:	142 ½" wide x 108" high
Number of glazing panels:	6
Max Glazing size: (Clear view)	44-11/32" wide x 86-5/8" high
Glazing:	Pyrobel 120-52 laminated glass

Assembly to be installed per manufacturers instructions.  
Allowable Configurations:

Rating:	120 minute
Frame:	Series 7000
Frame Gauge:	14
Glazing Thickness:	52 mm
Transom allowed:	No
Borrowed Lite allowed:	Yes
Sidelight allowed:	No
Fixed Door Panel allowed:	No
Max. Clear View:	44-11/32" wide x 86-5/8" high

\* Listed 60, 90 and 120 minute glazing rated and tested to ASTM E119 may be substituted. Wall system will have a rating equal to the glazing used to a maximum of 120 minutes.

<u>Attribute</u>	<u>Value</u>
Criteria	UL 263 (2003)
Criteria	NFPA 251 (2006)
Criteria	ASTM E119 (2008a)
Criteria	ASTM E119 (2010)
Criteria	UL 263 (2011)
Criteria	ASTM E119 (2016a)
CSI Code	08 44 00 Curtain Wall and Glazed Assemblies
Fire Resistance	2 Hour
Fire Resistance	1 Hour Fire Rating
Fire Resistance	1-1/2 Hour Fire Rating
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	OTHER PRODUCTS

Report Number 3094056-001rev, 3125351-01, 100225101COQ-002,  
10036586COQ-002, 100698313COQ-001,  
100786648COQ-001, 100980375MID-001  
Spec ID 40243